



SPECIFICATION FOR SUB-BASE AND LAYING COURSE:-THE CRUSHED STONE MUST POSSESS WELL DEFINED EDGES AND HAVE A MINIMUM 10% FINES VALUE OF 150KN WHEN TESTED IN ACCORDANCE WITH BS812 PART III.

SIEVE SIZE	% PASSING
100mm	100
63mm	90–100
37.5mm	60–80
20mm	15–30
10mm	0–5





REFER TO DRAWING: DEV-CSC-ZZ-XX-DR-C-0102 FOR CROSS  
SECTIONS LOCATIONS.

## NOTES

1. For setting out refer to Architect's drawings.
2. This drawing to be read in conjunction with all other Architectural and Engineering drawings and all other relevant drawings and Specifications.
3. **DO NOT SCALE THIS DRAWING.** Use figured dimensions only.
4. No part of this document may be reproduced or transmitted in any form or stored in any retrieval system of any nature without the written permission as copyright holder except as agreed for use on the project for which the document was originally issued.
5. Ordnance Survey Ireland Licence Number EN 0074022

[illegible]

Client Project	COADY ARCHITECTS DEVELOPMENT AT DEVROY BARRACKS, NAAS				<b>CS Consulting Group</b> DUBLIN   LONDON   LIMERICK			
	Title  PROPOSED CROSS SECTIONS				Head Office 19-22 Dame Street, Dublin 2. T: +353 (0)1 5480863 F: +353 (0)1 9011355 e: info@csconsulting.ie w: www.csconsulting.ie			
Dwg. No.	DEV-CSC-00-XX-DR-C-0122				 Quality Environment Energy Health & Safety			
Date	Dm by	Chk by	Apprv by	Scale	Revision	 I.S. EN ISO 9001:2008 I.S. EN ISO 14001:2004 I.S. EN ISO 50001:2011 OHSAS 18001:2007		
July 21	AB	GLB	NB	AS SHOWN @A1	<b>P02</b>			